

**Approved consolidated baseline and monitoring methodology ACM0007****“Baseline-Consolidated methodology for conversion from single cycle to combined cycle power generation”****I. SOURCE AND APPLICABILITY****Sources**

This consolidated baseline and monitoring methodology is based on elements from the following methodologies:

- NM0070: Conversion of existing open cycle gas turbine to combined cycle operation at Guaracachi power station, Santa Cruz, Bolivia whose Baseline study, Monitoring and Verification Plan and Project Design Document were prepared by KPMG, London;
- NM0078-rev: Conversion of single cycle to combined cycle power generation, Ghana whose Baseline study, Monitoring and Verification Plan and Project Design Document were prepared by Quality Tonnes and The Energy Foundation.

This methodology also refers to the latest approved versions of the following tools:

- “Tool to calculate the emission factor for an electricity system”;
- “Combined tool to identify the baseline scenario and demonstrate additionality”;
- “Tool to determine the remaining lifetime of equipment”;
- “Tool to calculate project or leakage CO<sub>2</sub> emissions from fossil fuel combustion”.

For more information regarding the proposed new methodologies and the tools as well as their consideration by the CDM Executive Board (the Board) please refer to <http://cdm.unfccc.int/goto/MPappmeth>.

**Selected approach from paragraph 48 of the CDM modalities and procedures**

“Existing actual or historical emissions, as applicable”

or

“Emissions from a technology that represents an economically attractive course of action, taking into account barriers to investment”.

**Applicability**

This methodology applies to project activities that utilize previously-unused<sup>1</sup> waste heat from a power plant, with a single-cycle capacity, be it a gas turbine or an internal combustion engine and utilize the heat to produce steam for a turbine – thus making the system combined-cycle.

---

<sup>1</sup> The fact that heat streams have been previously unused is demonstrated by the project participant by providing documents such as original process diagrams and schemes from the construction of the plant or/and on-site checks if no equipment for heat recovery had been/is installed.



This methodology is applicable under the following conditions:

- When project developers utilize previously unused<sup>2</sup> waste heat from a power plant, with a single-cycle capacity, be it a gas turbine or an internal combustion engine and utilize the heat to produce steam for a turbine – thus making the system combined cycle;
- When waste heat generated on site is not utilizable for any other purpose on-site;
- Where the project activity does not increase the lifetime of the existing gas turbine or engine during the crediting period, determined using the “Tool to determine the remaining lifetime of equipment”; (i.e. this methodology is applicable up to the end of the lifetime of existing gas turbine or engine, if shorter than crediting period);
- Where project developers have access to appropriate data to estimate the combined margin emission factor, as described in the “Tool to calculate the emission factor for an electricity system”, of the electricity grid to which the proposed project is connected.

In addition, the applicability conditions included in the tools referred to above apply. This baseline methodology shall be used in conjunction with the approved consolidated monitoring methodology ACM0007 (Monitoring methodology for conversion from single cycle to combined cycle power generation).

## II. BASELINE METHODOLOGY

### Project boundary

The spatial extent of the project boundary encompasses the power plant at the project site and all power plants connected physically to the electricity system that the CDM project power plant is connected to. The spatial extent of the project electricity system, including issues related to the calculation of the build margin (BM) and operating margin (OM), is defined in “Tool to calculate the emission factor for an electricity system”.

For the purpose of determining GHG emissions of the project activity, project participants shall include the following emissions sources:

- CO<sub>2</sub> emissions from on-site fuel consumption of fossil fuels for operation of the gas turbine or engine; and
- CO<sub>2</sub> emissions from on-site fuel consumption, to supplement the waste heat generated from gas turbine or engine, in generating steam to operate the steam turbine.

For the purpose of determining the baseline, project participants shall include the following emission sources:

- CO<sub>2</sub> emissions from fossil fuel fired power plants connected to the electricity system and in the operating and build margin;
- CO<sub>2</sub> emissions from operation of project power plant in open cycle mode.

<sup>2</sup> The fact that heat streams have been previously unused is demonstrated by the project participant by providing documents such as original process diagrams and schemes from the construction of the plant or/and on-site checks if no equipment for heat recovery had been/is installed.



The **spatial extent** of the project boundary encompasses the power plant at the project site and all power plants connected physically to the electricity system that the CDM project power plant is connected to. The spatial extent of the of the project electricity system, including issues related to the calculation of the build margin (BM) and operating margin (OM), is as per that defined in “Tool to calculate the emission factor for an electricity system”<sup>3</sup>.

The greenhouse gases included in or excluded from the project boundary are shown in Table 1. Table 1 illustrates which emissions sources are included and which are excluded from the project boundary for determination of both baseline and project emissions.

**Table 1: Overview on Emissions sources included in or excluded from the project boundary**

	Source	Gas	Included?	Justification / Explanation
Baseline Scenario	Baseline: Grid electricity generation	CO <sub>2</sub>	Included Yes	Main emission source
		CH <sub>4</sub>	Excluded No	Excluded for simplification. This is conservative
		N <sub>2</sub> O	Excluded No	Excluded for simplification. This is conservative
	On-site fossil fuel consumption to operate project power plant in open cycle mode.	CO <sub>2</sub>	Included Yes	An important emission source
		CH <sub>4</sub>	Excluded No	Excluded for simplification. This emission source is assumed to be very small
		N <sub>2</sub> O	Excluded No	Excluded for simplification. This emission source is assumed to be very small
Project Activity	On-site fossil fuel consumption to operate the gas turbine or engine of project power plant.	CO <sub>2</sub>	Included Yes	An important emission source
		CH <sub>4</sub>	Excluded No	Excluded for simplification. This emission source is assumed to be very small
		N <sub>2</sub> O	Excluded No	Excluded for simplification. This emission source is assumed to be very small
	On-site fossil fuel consumption to supplement waste heat in operating Steam turbine.	CO <sub>2</sub>	Included Yes	May be an important emission source
		CH <sub>4</sub>	Excluded No	Excluded for simplification. This emission source is assumed to be very small
		N <sub>2</sub> O	Excluded No	Excluded for simplification. This emission source is assumed to be very small

### Procedure for the selection of the **most plausible** baseline scenario and the demonstration of **additionality**

Project participants shall identify the most plausible baseline scenario and demonstrate additionality using the latest approved version of the “Combined tool to identify the baseline scenario and demonstrate additionality” agreed by the Board, available at the UNFCCC CDM web site.<sup>3</sup>

In applying the tool, realistic and credible alternatives should be separately determined regarding how power would be generated in the absence of the CDM project activity.

<sup>3</sup> Please refer to <<http://cdm.unfccc.int/methodologies/PAmethodologies/approved.html>>.



In evaluating the identified alternative baseline scenarios for their compliance with applicable regulations in the framework of the Combined Tool, the following regulations should be taken into account *inter alia*:

- Regulations for utilization of waste heat on the premises where it is generated;
- Regulation on energy efficiency norms for power projects; and
- Emission norms for power projects.

Alternatives that are not in compliance with existing regulations should be removed from further assessment.

When the current practice condition (to continue the operation in open cycle) is assessed, the future estimated load factor should reflect the changes due to new conditions in the grid, analyzing the last plants that have been incorporated in the grid.

Project proponents, if undertaking investment analysis, shall include the revenue generated from the possible increase in electricity produced from the open cycle component in the project situation.

This methodology is only applicable where it can be demonstrated that the baseline scenario is the continuation of the current practice, i.e. that in the absence of the proposed project activity the electricity, to meet the demand in the grid system, will be generated:

- (1) By the operation of the existing power plant in open cycle mode;
- (2) By the operation of existing grid-connected power plants; and
- (3) By the addition of new generation sources to the grid.

#### **Project boundary**

For the purpose of determining GHG emissions of the **project activity**, project participants shall include the following emissions sources:

- CO<sub>2</sub> emissions from on-site fuel consumption of fossil fuels for operation of the gas turbine or engine; and
- CO<sub>2</sub> emissions from on-site fuel consumption, to supplement the waste heat generated from gas turbine or engine, in generating steam to operate the steam turbine.

For the purpose of determining the **baseline**, project participants shall include the following emission sources:

- CO<sub>2</sub> emissions from fossil fuel fired power plants connected to the electricity system and in the operating and build margin;
- CO<sub>2</sub> emissions from operation of project power plant in open cycle mode.

The **spatial extent** of the project boundary encompasses the power plant at the project site and all power plants connected physically to the electricity system that the CDM project power plant is connected to. The spatial extent of the of the project electricity system, including issues related to the calculation of the



build margin (BM) and operating margin (OM), is as per that defined in “Tool to calculate the emission factor for an electricity system”.

Table 1 illustrates which emissions sources are included and which are excluded from the project boundary for determination of both baseline and project emissions.

**Table 2: Overview on emissions sources included in or excluded from the project boundary**

	Source	Gas		Justification / Explanation
Baseline Scenario	Baseline: Grid electricity generation	CO <sub>2</sub>	Included	Main emission source.
		CH <sub>4</sub>	Excluded	Excluded for simplification. This is conservative.
		N <sub>2</sub> O	Excluded	Excluded for simplification. This is conservative.
	On-site fossil fuel consumption to operate project power plant in open cycle mode.	CO <sub>2</sub>	Included	An important emission source.
		CH <sub>4</sub>	Excluded	Excluded for simplification. This emission source is assumed to be very small.
		N <sub>2</sub> O	Excluded	Excluded for simplification. This emission source is assumed to be very small.
Project Activity	On-site fossil fuel consumption to operate the gas turbine or engine of project power plant.	CO <sub>2</sub>	Included	An important emission source
		CH <sub>4</sub>	Excluded	Excluded for simplification. This emission source is assumed to be very small.
		N <sub>2</sub> O	Excluded	Excluded for simplification. This emission source is assumed to be very small.
	On-site fossil fuel consumption to supplement waste heat in operating Steam turbine.	CO <sub>2</sub>	Included	May be an important emission source
		CH <sub>4</sub>	Excluded	Excluded for simplification. This emission source is assumed to be very small.
		N <sub>2</sub> O	Excluded	Excluded for simplification. This emission source is assumed to be very small.

**Emission Reduction**

Annual emission reductions are calculated as follows: The project activity mainly reduces CO<sub>2</sub> emissions through substitution of power generation supplied by the existing generation sources connected to the grid and likely future additions to the grid. The emission reduction (ER<sub>y</sub>) by the project activity during year y is the difference between the baseline emissions (BE<sub>y</sub>), project emissions (PE<sub>y</sub>) and emissions due to leakage (LE<sub>y</sub>), and can be expressed as follows:

$$ER_y = BE_y - PE_y - LE_y \tag{1}$$

Where:

- ER<sub>y</sub> = Emissions reductions in year y (tCO<sub>2</sub>) are the emissions reductions due to the project activity during the year y in tons of CO<sub>2</sub>.
- BE<sub>y</sub> = Baseline emissions in year y (tCO<sub>2</sub>) are the baseline emissions due to displacement of electricity during the year y in tons of CO<sub>2</sub>.
- PE<sub>y</sub> = Project emissions in year y (tCO<sub>2</sub>) are the project emissions during the year y in tons of CO<sub>2</sub>.
- LE<sub>y</sub> = Leakage emissions in year y (tCO<sub>2</sub>) are the leakage emissions during the year y in tons of CO<sub>2</sub>.

**Project activity emissions**

Project emissions ( $PE_y$ ) should be calculated based on “Tool to calculate project or leakage CO<sub>2</sub> emissions from fossil fuel combustion” and is referred to in the Tool as  $PE_{FC,j,y}$ , making the element processes  $j$  correspond to the combustion of fossil fuels in year  $y$  include emissions from the use of fossil fuel to operate the gas turbine or engine ( $PEGT_y$ ) and emissions from the use of supplementary fossil fuel used in order to operate the steam turbine ( $PEST_y$ ).

$$PE_y = PEGT_y + PEST_y \quad (2)$$

$$PEGT_y = \sum_i FGT_{i,y} * NCV_i * EF_{CO_2,i} \quad (3)$$

$$PEST_y = \sum_j FST_{j,y} * NCV_j * EF_{CO_2,j} \quad (4)$$

where:

$FGT_{i,y}$	is the amount of fuel $i$ (in a mass or volume unit) consumed to operate the gas turbine or engine by the project in year $y$ .
$FST_{j,y}$	is the supplementary fuel $j$ (in mass or volume units) consumed in Heat Recovery Steam Generator (HRSG) to operate Steam turbine by the project in year $y$ .
$NCV$	is the net calorific value (energy content) per mass or volume unit of the fuel used.
$EF_{CO_2}$	is the CO <sub>2</sub> emission factor per unit of energy of the fuel used.

**Baseline emissions due to displacement of electricity**

The baseline scenario is the following: electricity would be generated by the operation of the power plant in open cycle mode, and by grid-connected power plants. The baseline emissions for year  $y$  (with assumption made regarding the baseline situation) are calculated as follows:

$$BE_{X,y} = (EF_{OC} * OG_{X,y}) + (EF_{grid,y} * (PG_y - OG_{X,y})) \quad (5)$$

$$BE_{X,y} = EF_{OC} * EG_{OC,X,y} + EF_{grid,y} * (EG_{CC,y} - EG_{OC,X,y}) \quad (2)$$

Where:

$EF_{OC}$	= Emission factor for plant operational in Open Cycle Mode in (tCO <sub>2</sub> /MWh)
$OG_{X,y}$ , $EG_{OC,X,y}$	= Electricity generated by the open cycle in the baseline (in MWh); as shown below, this is calculated in two ways based on historical data ( $OG_{H,y}$ , $EG_{OC,H,y}$ ), or based on the load factor in the project plant ( $EG_{OC,P,y}$ , $OG_{P,y}$ ) and Index $X$ is either “H” or “P”
$PG_y$ , $EG_{CC,y}$	= is actual Actual electricity generated by project in year $y$ (MWh)
$EF_{grid,y}$	= is the CO <sub>2</sub> emission factor for the electricity displaced due to the project activity during the year $y$ in tones (tCO <sub>2</sub> /MWh)



If more than one fuel is used in the gas turbine or engine, the baseline calculation (equation 52) must assume the emission factor of the **less intensive carbon** **least carbon intensive** fuel that has been used before or after project implementation.

**Step 1: Estimating  $EG_{OC,x,y}$   $OG_{x,y}$**

Project participants shall estimate, by the two ways provided below, the amount of generation by the power plant running in open cycle mode in the baseline ( $in$  MWh). The calculation is done based on:

(i) The historic load situation ( $EG_{OC,H,y}$   $OG_{H,y}$ ) and for (ii) The load situation in the project ( $EG_{OC,P,y}$   $OG_{P,y}$ ), as follows:

(i) Amount of baseline power generation assuming on historical data ( $in$  MWh):

$$\frac{OG_{H,y}}{HG_{OC}}$$

$$EG_{OC,H,y} = EG_{OC} \quad (3)$$

Where:

$HG_{OC}$   $EG_{OC}$  = **is the a**verage net annual generation from the operation of power plant in open cycle mode based on five years of generation records **previous to start of the project at the time of validation** ( $in$  MWh). If five years data is not available, then data for the highest number of complete years available should be used, with a minimum of three full years

(ii) And amount of baseline power generation calculated assuming load situation of project power plant ( $in$  MWh):

$$\frac{OG_{P,y}}{PC} = \frac{OC}{PC} \times PG_y$$

$$EG_{OC,P,y} = \frac{Cap_{OC}}{Cap_{CC}} \times EG_{CC,y} \quad (4)$$

Where:

$OC$   $Cap_{OC}$  = **is the n**et power generation capacity<sup>4</sup> of the open cycle gas turbine or engine before the project activity ( $in$  MW)

$PG_{CC,y}$  = **is a**Actual electricity generated by project in year  $y$  (MWh)

$PC$   $Cap_{CC}$  = **is n**et installed power generation capacity (MW) of the project including both the open cycle (gas turbine or engine) and the steam turbine capacity

<sup>4</sup> Net capacity is defined as gross capacity less auxiliary consumption of the plant.



### Step 2: Estimating $EF_{OC}$ , the emissions factor for electricity generated in open cycle mode in the baseline

The emissions factor for the open cycle mode generation in the baseline ( $EF_{OC}$  in  $tCO_2/MWh$ ) is given by historical performance of the plant when it operated in open cycle using data for five years<sup>5</sup> previous to the start of project at the time of validation. The emission factor is calculated as follows:

$$EF_{OC} = \frac{FC_{HIST}}{HG_{OC}} \times NCV \times EF_{CO_2} \quad (8)$$

$$EF_{OC} = \frac{FC_{HIST}}{EG_{OC}} \times NCV \times EF_{CO_2} \quad (5)$$

Where:

- $FC_{HIST}$  = Annual average fuel consumption of the open cycle gas turbine or engine (in mass of or volume units) estimated using data for five years previous to start of the project at the time of validation. If five years data is not available, then data for the highest number of complete years available should be used, with a minimum of three full years
- $EHG_{OC,x}$  = is the average net annual generation from the operation of power plant in open cycle mode based on 'x' years of generation records previous to start of the project (in MWh)
- $NCV$  = is the net calorific value of the fuel (energy content) per GJ/mass or volume unit of the fuel
- $EF_{CO_2}$  = is the  $CO_2$  emission factor per unit of energy of the fuel ( $tCO_2/GJ$ )

### Step 3: Determine the emissions factor for the operating margin

The baseline emission factor ( $EF_{grid,y}$ ) should be calculated as a combined margin (CM), following the guidance in the “Tool to calculate the emission factor for an electricity system”.

If project proponents use the dispatch data analysis method, as described in the “Tool to calculate the emission factor for an electricity system”, the following modification applies:

The group  $n$  of power plants in the dispatch margin is set of power plants in the top  $x\%$  of total electricity dispatched by the grid system during hour  $h$ , where  $x\%$  is equal to the greater of either:

- 10%; or
- The project generation during hour  $h$  expressed as a percentage of the total grid generation for that hour.

Project proponents can use the efficiency of the plant to estimate combined margin emission factor if fuel data for plants is not available. The volume of fuel consumed by each plant can be calculated using the efficiency of the plant and the electricity output. The efficiencies of the units attached to the grid should be from publicly verifiable sources. In case of multiple sources and values of efficiency one which results in most conservative estimate of emission factor should be used.

<sup>5</sup> If five years data is not available then data for the most number of complete years available should be used, with a minimum of one full year.

**Step 4: Conservatively determine baseline emissions**

The baseline emission  $BE_y$  for year  $y$  is the lower value between the baseline emissions calculated on the basis of historical power generation,  $BE_{H,y}$ , and the baseline emissions calculated based on the load factor of the project situation,  $BE_{P,y}$ :

$$BE_y = \text{MIN}(BE_{H,y}, BE_{P,y}) \quad (6)$$

Where  $BE_{H,y}$  and  $BE_{P,y}$  are determined with equations (25) to (58).

**Leakage**

The main emissions potentially giving rise to leakage in the context of the proposed projects are:

- (i) CH<sub>4</sub> leakage in production, transportation and consumption of increased quantity of natural gas consumed by the project activity; and
- (ii) Emissions arising due to power plant construction.

The CH<sub>4</sub> emissions can be ignored while applying this methodology, if project proponents demonstrate through estimation that these are a negligible fraction of baseline.

Project participants do not need to consider construction related emission sources as leakage in applying this methodology. Project activities using this baseline methodology shall not claim any credit for the project on account of reducing these emissions below the level of the baseline scenario.

**Data and parameters not monitored**

In addition to the parameters listed in the tables below, the provisions on data and parameters not monitored in the tools referred to in this methodology apply.

<b>Data / Parameter:</b>	$HE_{GOC}$
Data unit:	MWh
Description:	Historical net quantity of electricity generated by the Open Cycle operation of power plant
Source of data:	Generation records. Historical data of electricity supplied by the project to the grid, preferably for five year <del>previous to the start of project</del> should be used and not less than three years
Measurement procedures (if any):	
Any comment:	The consistency of metered net electricity generation should be cross-checked with receipts from sales (if available) <del>and the quantity of biomass fired (e.g. check whether the electricity generation divided by the quantity of biomass fired results in a reasonable efficiency that is comparable to previous years)</del> . Meters should be subject to regular maintenance and testing regime to ensure efficiency



<b>Data / Parameter:</b>	$OC_{CapOC}$
Data unit:	MW
Description:	Net power generation capacity <sup>6</sup> of the open cycle gas turbine or engine (before the project activity)
Source of data:	Manufacturer's specification
Measurement procedures (if any):	
Any comment:	Capacity of the project power plant in combined cycle operation be given as declared net capacity

<b>Data / Parameter:</b>	$PC_{CapCC}$
Data unit:	MW
Description:	Net generation capacity of the project power plant
Source of data:	Manufacturer's specification
Measurement procedures (if any):	
Any comment:	Capacity of the project power plant in combined cycle operation be given as declared net capacity

<b>Data / Parameter:</b>	$FC_{HIST}$
Data unit:	Mass or Volume
Description:	Historic Fuel consumption of the project in Open cycle generation
Source of data:	Historical data of annual fuel consumption by the project operating in open cycle mode, preferably based on data for five years previous to the start of project and not less than three years.
Measurement procedures (if any):	
Any comment:	The data for any direct measurements with mass or volume meters at the plant site should be cross-checked with an annual energy balance that is based on purchased quantities and stock changes. Meters should be subject to regular maintenance and testing regime to ensure efficiency

<sup>6</sup> Net capacity is defined as gross capacity less auxiliary consumption of the plant.



<b>Data / Parameter:</b>	NCV										
Data unit:	GJ / mass or volume unit										
Description:	Net calorific value of fossil fuel type used previous to the start of project										
Source of data:	<p>The following data sources may be used if the relevant conditions apply:</p> <table border="1"> <thead> <tr> <th>Data source</th> <th>Conditions for using the data source</th> </tr> </thead> <tbody> <tr> <td>(a) Values provided by the fuel supplier in invoices</td> <td>This is the preferred source</td> </tr> <tr> <td>(b) Measurements by the project participants</td> <td>If (a) is not available</td> </tr> <tr> <td>(c) Regional or national default values</td> <td>If (a) is not available  These sources can only be used for liquid fuels and should be based on well documented, reliable sources (such as national energy balances).</td> </tr> <tr> <td>(d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in Table 1.2 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories</td> <td>If (a) is not available</td> </tr> </tbody> </table>	Data source	Conditions for using the data source	(a) Values provided by the fuel supplier in invoices	This is the preferred source	(b) Measurements by the project participants	If (a) is not available	(c) Regional or national default values	If (a) is not available  These sources can only be used for liquid fuels and should be based on well documented, reliable sources (such as national energy balances).	(d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in Table 1.2 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	If (a) is not available
Data source	Conditions for using the data source										
(a) Values provided by the fuel supplier in invoices	This is the preferred source										
(b) Measurements by the project participants	If (a) is not available										
(c) Regional or national default values	If (a) is not available  These sources can only be used for liquid fuels and should be based on well documented, reliable sources (such as national energy balances).										
(d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in Table 1.2 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	If (a) is not available										
Measurement procedures (if any):	<p>For (a) and (b): measurements should be undertaken in line with national or international fuel standards. The NCV should be obtained for each fuel delivery, from which weighted average annual values should be calculated</p> <p>For (c): review appropriateness of the values annually</p> <p>For (d): any future revision of the IPCC Guidelines should be taken into account</p>										
Any comment:	<p>If more than one fuel is used in the gas turbine or engine, the NCV of the least carbon intensive fuel that has been used before or after project implementation, should be determined.</p> <p>The data corresponds to the historic fuel use. Check consistency of measurements and local / national data with default values by the IPCC. If the values differ significantly from IPCC default values, possibly collect additional information or conduct measurements. Verify if the values under (a), (b) and (c) are within the uncertainty range of the IPCC default values as provided in Table 1.2, Vol. 2 of the 2006 IPCC Guidelines. If the values fall below this range collect additional information from the testing laboratory to justify the outcome or conduct additional measurements. The laboratories in (a), (b) or (c) should have ISO17025 accreditation or justify that they can comply with similar quality standards</p>										



<b>Data / Parameter:</b>	EF <sub>CO2</sub>											
<b>Data unit:</b>	tCO <sub>2</sub> /GJ											
<b>Description:</b>	CO <sub>2</sub> emission factor for fossil fuel used previous to the start of project											
<b>Source of data:</b>	<p>The following data sources may be used if the relevant conditions apply:</p> <table border="1"> <thead> <tr> <th>Data source</th> <th>Conditions for using the data source</th> </tr> </thead> <tbody> <tr> <td>(a) Values provided by the fuel supplier in invoices</td> <td>This is the preferred source</td> </tr> <tr> <td>(b) Measurements by the project participants</td> <td>If (a) is not available</td> </tr> <tr> <td>(c) Regional or national default values</td> <td>If (a) is not available  These sources can only be used for liquid fuels and should be based on well-documented, reliable sources (such as national energy balances)</td> </tr> <tr> <td>(d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories</td> <td>If (a) is not available</td> </tr> </tbody> </table>		Data source	Conditions for using the data source	(a) Values provided by the fuel supplier in invoices	This is the preferred source	(b) Measurements by the project participants	If (a) is not available	(c) Regional or national default values	If (a) is not available  These sources can only be used for liquid fuels and should be based on well-documented, reliable sources (such as national energy balances)	(d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	If (a) is not available
Data source	Conditions for using the data source											
(a) Values provided by the fuel supplier in invoices	This is the preferred source											
(b) Measurements by the project participants	If (a) is not available											
(c) Regional or national default values	If (a) is not available  These sources can only be used for liquid fuels and should be based on well-documented, reliable sources (such as national energy balances)											
(d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	If (a) is not available											
<b>Measurement procedures (if any):</b>	<p>For (a) and 9b): measurements should be undertaken in line with national or international fuel standards. The NCV should be obtained for each fuel delivery, from which weighted average annual values should be calculated</p> <p>For (c): review appropriateness of the values annually</p> <p>For (d): any future revision of the IPCC Guidelines should be taken into account</p>											
<b>Any comment:</b>	<p>If more than one fuel is used in the gas turbine or engine, the emission factor of the least carbon intensive fuel that has been used before or after project implementation, should be determined.</p> <p>The data corresponds to the historic fuel use. Check consistency of measurements and local / national data with default values by the IPCC. If the values differ significantly from IPCC default values, possibly collect additional information or conduct measurements. Verify if the values under a), b) and c) are within the uncertainty range of the IPCC default values as provided in Table 1.3, Vol. 2 of the 2006 IPCC Guidelines. If the values fall below this range collect additional information from the testing laboratory to justify the outcome or conduct additional measurements. The laboratories in (a), (b) or (c) should have ISO17025 accreditation or justify that they can comply with similar quality standards</p>											

**III. MONITORING METHODOLOGY**

All data collected as part of monitoring should be archived electronically and be kept at least for two years after the end of the last crediting period. One hundred per cent of the data should be monitored if not indicated otherwise in the tables below. All measurements should be conducted with calibrated measurement equipment according to relevant industry standards.

In addition, the monitoring provisions in the tools referred to in this methodology apply.

**Data and parameters monitored**

<b>Data / Parameter:</b>	$PEG_{CC,y}$
Data unit:	MWh
Description:	Net quantity of electricity generated by the project power plant in year $y$
Source of data:	Manufacturer's specification
Measurement procedures (if any):	
Monitoring frequency:	Continuously
QA/QC procedures:	The consistency of metered net electricity generation should be cross-checked with receipts from sales (if available) and the quantity of biomass fired (e.g. check whether the electricity generation divided by the quantity of biomass fired results in a reasonable efficiency that is comparable to previous years). Meters should be subject to regular maintenance and testing regime to ensure efficiency.
Any comment:	

**Revision to the approved consolidated monitoring methodology ACM0007****“Monitoring methodology for conversion from single cycle to combined cycle power generation”****Sources**

This Monitoring methodology is based on elements from the following methodologies:

- NM0070: Conversion of existing open cycle gas turbine to combined cycle operation at Guaracachi power station, Santa Cruz, Bolivia whose Baseline study, Monitoring and Verification Plan and Project Design Document were prepared by KPMG, London; and
- NM0078- rev: Conversion of single cycle to combined cycle power generation, Ghana whose Baseline study, Monitoring and Verification Plan and Project Design Document were prepared by Quality Tonnes and The Energy Foundation.

For more information regarding the proposals and their consideration by the Executive Board please refer to <http://cdm.unfccc.int/goto/MPappmeth>



This methodology also refers to the latest approved versions of the “Tool to calculate the emission factor for an electricity system” and the “Tool for the demonstration and assessment of additionality”<sup>7</sup>.

### **Applicability**

This monitoring methodology shall be used in conjunction with the approved consolidated baseline methodology ACM0007 (Baseline methodology for conversion from single cycle to combined cycle power generation). The same applicability conditions as in baseline ACM0007 apply.

### **Monitoring Methodology**

The monitoring methodology requires monitoring of the following:

- Electricity generation from the proposed project activity;
- Fuel consumption from the proposed project activity;
- Data needed to recalculate the emissions attributable to the operation of the gas turbines or engines in open cycle under the baseline scenario, consistent with baseline methodology “Baseline methodology for replacing grid-based power by emissions neutral power from existing fossil fuel powered facilities using previously unused waste heat”;
- Data needed to recalculate the operating margin (OM) emission factor, based on the choice of the method to determine the OM, consistent with the “Tool to calculate the emission factor for an electricity system”; and
- Data needed to recalculate the build margin emission factor, consistent with the “Tool to calculate the emission factor for an electricity system”.

<sup>7</sup> Please refer to <http://cdm.unfccc.int/goto/MPappmeth>

**Project emissions parameters**

Project participants should establish a system to monitor the amount of all types of fossil fuel combusted. On-site fossil fuel consumption for the operation of the power plant should be metered through flow or volume meters or respectively with an energy balance over the year, considering stocks at the beginning and at the end of each year. Where possible, project participants should cross-check these estimates with fuel purchase receipts. The following table lists the data to be collected or used in order to monitor emissions from the project activity.

ID number	Data Type	Data variable	Data unit	Measured (m) calculated (e) estimated (e)	Recording frequency	Proportion of data monitored	How will data be archived? (electronic/ paper)	For how long is archived data kept?	Comment
1. FGT <sub>j,y</sub>	Mass or Volume		Mass or volume unit of the fuel	M	Hourly, prepare annually an energy balance	100%	Electronic	During the Crediting Period.	The quantity of fossil fuel combusted should be collected separately for all types of fossil fuel.
2. FST <sub>j,y</sub>	Mass or Volume	Consumption of fuel j of project during the year for operating Steam Turbine	Mass or volume unit of the fuel	M	Hourly, prepare annually an energy balance	100%	Electronic	During the Crediting Period.	The quantity of fossil fuel combusted should be collected separately for all types of fossil fuel.
3. NCV	Net calorific value	Net calorific value of fossil fuel	GJ/ mass or volume unit	M or C	Annually	100%	Electronic	During the crediting period	The net calorific value should be determined separately for all types of fossil fuels. Net calorific values should be based on measurements or reliable local or national data.



ID number	Data Type	Data variable	Data unit	Measured (m) calculated (c) estimated (e)	Recording frequency	Pro-portion of data monitored	How will data be archived? (electronic/ paper)	For how long is archived data kept?	Comment
4. EF <sub>CO2</sub>	Emissions factor	CO <sub>2</sub> emission factor for fossil	tCO <sub>2</sub> /GJ	M	Annually	100%	Electronic	During the crediting period.	Net calorific values should be based on measurements or reliable local or national data. If local or national data is not available appropriate IPCC default can be used.



ID number	Data Type	Data variable	Data unit	Measured (m) calculated (e) estimated (e)	Recording frequency	Pro-portion of data monitored	How will data be archived? (electronic/ paper)	For how long is archived data kept?	Comment
	Electricity quantity	∫		M	Yearly	100%	Electronic	During the crediting period.	
	Electricity quantity			M		100%	Electronic	During the crediting period.	
	Electricity Generation Capacity	∫		M		100%	Electronic	During the crediting period.	
	Fuel quantity	∫		M	Once in crediting period	100%	Electronic	During the crediting period.	
	Net calorific value	∫		m or e	Annually	100%	Electronic	During the crediting period.	
	Emissions factor	∫		M	Annually	100%	Electronic	During the crediting period.	
	Electricity Generation Capacity			M	Once in crediting period	100%	Electronic	During the crediting period.	

**Leakage**

No data required as Leakage are assumed negligible.

**Quality Control (QC) and Quality Assurance (QA) Procedures**

All measurements should use calibrated measurement equipment that is maintained regularly and checked for its functioning. QA/QC procedures for the parameters to be monitored are illustrated in the following table.

<b>Data</b>	<b>Uncertainty Level of Data (High/Medium/Low)</b>	<b>Are QA/QC procedures planned for these data?</b>	<b>Outline explanation how QA/QC procedures are planned</b>
1, 2, 8	Low	Yes	
3, 4, 9, 10	Low	Yes	
5, 6	Low	Yes	

-----



## History of the document

Version	Date	Nature of Revision
04	EB 55, Annex 11 30 July 2010	<ul style="list-style-type: none"><li>Annual average fuel consumption of the open cycle gas turbine or engine may be estimated using data from five years previous to start of the project at the time of validation. If five years data is not available, then data for the highest number of complete years available, but not less than three, should be used;</li><li>References to "Tool to determine the remaining lifetime of equipment" and "Tool to calculate project or leakage CO2 emissions from fossil fuel combustion" were added;</li><li>The format of the methodology was updated.</li></ul>
03	EB 35, Paragraph 24 02 November 2007	The reference to ACM0002 was replaced by a reference to "Tool to calculate the emission factor for an electricity system".
02	EB 31, Annex 9 02 May 2007	The applicability of the approved methodology was expanded to single cycle engine systems.
01	EB 22, Annex 9 28 November 2005	Initial adoption.
<b>Decision Class:</b> Regulatory <b>Document Type:</b> Standard <b>Business Function:</b> Methodology		