

**Annex 39****Registration****Scope of the review on
“340 MW Gas based combined cycle power project expansion at Hazira” (2915)**

1. The Board agreed to undertake a review of a project activity “340 MW Gas based combined cycle power project expansion at Hazira” (2915).
2. The Board agreed that the scope of the review relating to issues associated with validation requirements shall cover a review to assess the application of the baseline and monitoring methodology through an assessment of suitability of the applied emission factor for upstream fugitive methane in calculating leakage in accordance with AM0029 v3 as use of the emission factor for upstream fugitive methane for USA and Canada (160 tCH₄/PJ) in calculating the leakage has not been adequately justified.

- - - - -

Project 2915	EB 55, Annex 39 30 July 2010	Decision Class: Ruling Document Type: Scope of Review Business Function: Registration
-----------------	---------------------------------	--